

**Aquarion Water Company
PFAS Sampling Results**

Woodbury System Results

All Results Reported as parts per trillion (ppt)

Water System Name	Sample Location	Test Date	PFOA	Effective 6/15/22	PFOS	Effective 6/15/22	PFHxS	Effective 6/15/22	PFNA	Effective 6/15/22
				CT DPH PFOA Action Level		CT DPH PFOS Action Level		CT DPH PFHxS Action Level		CT DPH PFNA Action Level
Woodbury	Woodbury Well 1, POE	May 2019	2	16	ND	10	ND	49	ND	12
	Woodbury Well 1, POE	Jun. 2021	ND		ND		ND			
	Woodbury Wells 2+3, POE	May 2019	4		7		0		ND	
	Woodbury Wells 2+3, POE	Jul. 2021	5		10		2		ND	
	Woodbury Wells 2+3, POE	Apr. 2022	7		12		2		ND	

Footnotes:

A yellow highlighted value denotes a historical concentration that is greater than the new Connecticut Department of Public Health Action Level established on June 15, 2022

Definitions:

ND - Not Detected

POE - Point of Entry. Sample collected after treatment as water enters the distribution system, before the first customer.