

Aquarion Water Company PFAS Sampling Results

Town/City: Easton, Fairfield, Newtown, Norwalk-Saugatuck Shores, Redding, Shelton, Stratford, Trumbull, Weston, Westport, and Wilton
Water System Name: Bridgeport Metro

All Results Reported as parts per trillion (ppt)

Sample Location	Test Date	PFOA	CT DPH PFOA Action Level*	PFOS	CT DPH PFOS Action Level*	PFHxS	CT DPH PFHxS Action Level*	PFNA	CT DPH PFNA Action Level*
Canal Street Wells, POE	Jun. 2019	4		5		4		ND	
	Jun. 2021	4		5		ND		ND	
	Aug. 2021	5		5		2		ND	
	Sep. 2022	5	16	6	10	ND	49	ND	12
Coleytown Wells, POE	Jun. 2019	4		4		ND		ND	
	Jun. 2021	7		4		ND		ND	
	Aug. 2021	8		5		2		ND	
	Jun. 2022	7	16	4	10	ND	49	ND	12
Easton Lake Reservoir, POE	Jun. 2019	3		ND		ND		ND	
	Jun. 2021	2		ND		ND		ND	
	Sep. 2022	3	16	2	10	ND	49	ND	12
Hemlocks Reservoir, POE	Jun. 2019	2		ND		ND		ND	
	Jun. 2021	ND		ND		ND		ND	
	Sep. 2022	3	16	ND	10	ND	49	ND	12
Trap Falls Reservoir, POE	Jun. 2019	5		ND		ND		ND	
	Jun. 2021	3		ND		ND		ND	
	Sep. 2022	4	16	ND	10	ND	49	ND	12
Housatonic Wells, POE - NOT IN SERVICE	—	—		—		—		—	

Footnotes:

* Following the most recent toxicological studies, on 06/15/2022 CT DPH replaced the existing 70 ppt guideline with the chemical-specific levels included above. The action levels shown above apply only to samples collected on or after 06/15/2022.

Definitions:

ND - Not Detected

POE - Point of Entry. Sample collected after treatment as water enters the distribution system, before the first customer.