

Aquarion Water Company PFAS Sampling Results

Town/City: Ridgefield
Water System Name: Craigmoor

All Results Reported as parts per trillion (ppt)

Sample Location	Test Date	PFOA	CT DPH PFOA Action Level*	PFOS	CT DPH PFOS Action Level*	PFHxS	CT DPH PFHxS Action Level*	PFNA	CT DPH PFNA Action Level*
Craigmoor Well, POE	Jun. 2019	5		9		4		ND	
	Aug. 2019	6		6		ND		ND	
	Feb. 2020	5		6		3		ND	
	Aug. 2020	5		5		2		ND	
	Nov. 2020	6		6		2		ND	
	Feb. 2021	4		6		3		ND	
	Jun. 2021	4		5		3		ND	
	Aug. 2021	6		8		3		ND	
	Apr. 2022	4		5		2		ND	

Footnotes:

* Following the most recent toxicological studies, on 06/15/2022 CT DPH replaced the existing 70 ppt guideline with the chemical-specific levels included above. The action levels shown above apply only to samples collected on or after 06/15/2022.

Definitions:

ND - Not Detected

POE - Point of Entry. Sample collected after treatment as water enters the distribution system, before the first customer.