

**Aquarion Water Company  
PFAS Sampling Results**

**Town/City: Oxford**

All Results Reported as parts per trillion (ppt)

Water System Name	Sample Location	Test Date	PFOA	PFOS	PFHpA	PFHxS	PFNA	PFDA	TOTAL	MASSDEP	Other PFAS Tested		
									PFAS (6)	MCL	PFBS	PFHxA	PFTA
Oxford	No. Main St Well #1, POE	2019 Q4 (Oct)	1	1	ND	ND	ND	ND	2	20	1	ND	ND
	No. Main St Well #1, POE	2021 Q4 (Oct)	ND	ND	ND	ND	ND	ND	ND	20	ND	ND	ND
	No. Main St Well #1, POE	2022 Q1 (Jan)	ND	ND	ND	ND	ND	ND	ND	20	ND	ND	ND
	No. Main St Well #2, POE	2019 Q4 (Oct)	1	1	ND	1	ND	ND	3	20	1	ND	ND
	No. Main St Well #2, POE	2021 Q4 (Oct)	ND	ND	ND	ND	ND	ND	ND	20	ND	ND	ND
	No. Main St Well #2, POE	2022 Q1 (Jan)	ND	ND	ND	ND	ND	ND	ND	20	ND	ND	ND
	Nelson St Wells #3, POE	2019 Q4 (Oct)	2	1	1	1	ND	ND	5	20	1	ND	ND
	Nelson St Wells #3, Raw	2020 Q2 (Apr)	2	ND	ND	ND	ND	ND	2	20	3	3	ND
	Nelson St Wells #3, POE	2021 Q4 (Oct)	3	ND	ND	ND	ND	ND	3	20	ND	3	ND
	Nelson St Wells #3, POE	2021 Q4 (Dec)	2	ND	ND	ND	ND	ND	2	20	ND	3	ND
	Nelson St Wells #3, POE	2022 Q1 (Jan)	2	ND	ND	ND	ND	ND	2	20	ND	3	ND

**Definitions:**

**MCL** - Maximum Contaminant Level

**ND** - Not Detected

**POE** - point of entry. Sample collected after treatment as water enters the distribution system, before the first customer.

**Raw** - Sample collected before treatment.