

**Aquarion Water Company of Massachusetts
PFAS Sampling Results**

Town/City: Sheffield

All Results Reported as parts per trillion (ppt)

Water System Name	Sample Location	Test Date	PFOA	PFOS	PFHpA	PFHxS	PFNA	PFDA	TOTAL	MassDEP	Other PFAS Tested with	
									PFAS (6)	MCL	Detections*	
Sheffield	Pike Well, 04G (POE)	Oct. 2021	ND	ND	ND	ND	ND	ND	ND	20	ND	ND
		Apr. 2022	ND	ND	ND	ND	ND	ND	ND	20	ND	ND
		May 2022	ND	ND	ND	ND	ND	ND	ND	20	ND	ND
		Jul. 2022	ND	ND	ND	ND	ND	ND	ND	20	ND	ND
	Maple Ave Well, 05G (POE)	Oct. 2021	ND	ND	ND	ND	ND	ND	ND	20	ND	ND
		Apr. 2022	ND	ND	ND	ND	ND	ND	ND	20	ND	ND
		May 2022	ND	ND	ND	ND	ND	ND	ND	20	ND	ND
		Jul. 2022	ND	ND	ND	ND	ND	ND	ND	20	ND	ND

Footnote:

*Other non-detect PFAS compounds are PFTA, HFPO-DA, ADONA, 9CI-PF3ONS, NMeFOSAA, PFUnA, NEtFOSAA, PFDoA, 11CI-PF3OUdS, and PFTrDA.

Definitions:

J -The result reported from the laboratory is below Minimum Reporting Level of 2 ppt, but greater than the Method Detection Limit. Per MassDEP, this value is not included in the compliance Total for PFAS (6).

MassDEP - Massachusetts Department of Environmental Protection

MCL - Maximum Contaminant Level

ND - Not Detected

POE - Point of Entry. Sample collected after treatment as water enters the distribution system, before the first customer.