

**Aquarion Water Company of Massachusetts
2022 PFAS Sampling Results**

Water System Name: Sheffield

All Results Reported as parts per trillion (ppt)

									TOTAL PFAS (6)	MassDEP MCL	Other PFAS Tested with Detections*	
Water System Name	Sample Location	Test Date	PFOA	PFOS	PFHpA	PFHxS	PFNA	PFDA			PFBS	PFHxA
Sheffield	Pike Well, 04G (POE)	Apr. 2022	ND	ND	ND	ND	ND	ND	ND	20	ND	ND
		May 2022	ND	ND	ND	ND	ND	ND	ND	20	ND	ND
		Jul. 2022	ND	ND	ND	ND	ND	ND	ND	20	ND	ND
	Maple Ave Well, 05G (POE)	Apr. 2022	ND	ND	ND	ND	ND	ND	ND	20	ND	ND
		May 2022	ND	ND	ND	ND	ND	ND	ND	20	ND	ND
		Jul. 2022	ND	ND	ND	ND	ND	ND	ND	20	ND	ND

Footnote:

*Other non-detect PFAS compounds are PFTA, HFPO-DA, ADONA, 9CI-PF3ONS, NMeFOSAA, PFUnA, NEtFOSAA, PFDoA, 11CI-PF3OUdS, and PFTrDA.

Definitions:

MassDEP - Massachusetts Department of Environmental Protection

MCL - Maximum Contaminant Level

ND - Not Detected

POE - Point of Entry. Sample collected after treatment as water enters the distribution system, before the first customer.