Aquarion Water Company of Massachusetts
Historic PFAS Sampling Results

Water System Name: Sheffield

All Results Reported as parts per trillion (ppt)

Water System Name	Sample Location	Test Date	PFOA	PFOS	PFHpA	PFHxS	PFNA	PFDA	**TOTAL PFAS (6)**	**MassDEP MCL**	Other PFAS Tested with Detections* PFBS	PFHxA
Sheffield	Pike Well, 04G (POE)	Oct. 2021	ND	ND	ND	ND	ND	ND	**ND**	**20**	ND	ND
	Maple Ave Well, 05G (POE)	Oct. 2021	ND	ND	ND	ND	ND	ND	**ND**	**20**	ND	ND

Footnote:
**Other non-detect PFAS compounds are PFTA, HFPO-DA, ADONA, 9Cl-PF3ONS, NMeFOSAA, PFUnA, NEtFOSAA, PFDoA, 11Cl-PF3OUdS, and PFTrDA.*

Definitions:
MassDEP - Massachusetts Department of Environmental Protection
MCL - Maximum Contaminant Level
ND - Not Detected
POE - Point of Entry. Sample collected after treatment as water enters the distribution system, before the first customer.

AQUARION Water Company
Stewards of the Environment