

Aquarion Water Company of Massachusetts
Historic PFAS Sampling Results

Town/City: Dover

Water System Name: Springdale Farms

All Results Reported as parts per trillion (ppt)

Water System Name: Springdale Farms									All results reported as parts per trillion (ppt)			
Water System Name	Sample Location	Test Date	PFOA	PFOS	PFHpA	PFHxS	PFNA	PFDA	TOTAL	MassDEP	Other PFAS Tested with	
									PFAS (6)	MCL	Detections*	
Springdale Farms	Springdale Wells, (POE)	Oct. 2021	7.8	6.5	2.6	J	J	ND	16.8	20	2.4	4.6
		Nov. 2021	9.1	6.7	3.1	J	J	ND	18.9	20	2.6	5.6

Footnotes:

*Other non-detect PFAS compounds are PFTA, HFPO-DA, ADONA, 9CI-PF3ONS, NMeFOSAA, PFUnA, NEtFOSAA, PFDoA, 11CI-PF3OUdS, and PFTrDA.

Definitions:

J -The result reported from the laboratory is below Minimum Reporting Level of 2 ppt, but greater than the Method Detection Limit. Per MassDEP, this value is not included in the compliance Total for PFAS (6).

MassDEP - Massachusetts Department of Environmental Protection

MCL - Maximum Contaminant Level

ND - Not Detected

POE - Point of Entry. Sample collected after treatment as water enters the distribution system, before the first customer.